

PORTABLE APPLIANCE TEST REGISTER

REGISTER NO.

Page 1 of 2

Di-LOG
 ...measurably better

Customer Name / Address: JAMES KENNEDY PRODUCTIONS

Date: 28/4/15

Contractor Name / Address: ENTERTAINMENT HQ

Engineer: J. KENNEDY

Test Equipment: Make UNI-T Model UT528

Serial No. 813016579

Appliance	Description	Class		Serial No	Visual Inspection				Earth Bond Continuity Ω	Insulation M Ω	Comment	Pass ✓	Fail x
		I	II		Fuse A	Plug (✓, x)	Flex (✓, x)	Body (✓, x)					
1	ENT0007		✓	—	3A	✓	✓	✓	—	19.99		✓	
2	ENT0008		✓	—	3A	✓	✓	✓	—	19.99		✓	
3	ENT0009		✓	—	3A	✓	✓	✓	—	19.99		✓	
4	ENT0010		✓	0015/7081	10A	✓	✓	✓	—	19.99		✓	
5	ENT0011	✓	✓	—	13A	✓	✓	✓	—	19.99		✓	
6	ENT0012	✓		4220470087	15A	✓	✓	✓	00.14	19.99		✓	
7	ENT0013	✓		4191020039	15A	✓	✓	✓	00.14	19.99		✓	
8	ENT0014	✓		12327	13A	✓	✓	✓	00.39	19.99		✓	
9	ENT0015	✓			13A	✓	✓	✓	00.39	19.99		✓	
10	ENT0016	✓			10A	✓	✓	✓	—	19.99		✓	
11	ENT0017	✓			10A	✓	✓	✓	—	19.99		✓	
12	ENT0018	✓			13A	✓	✓	✓	00.19	19.99		✓	
13	ENT0019	✓		80090594805	13A	✓	✓	✓	—	19.99		✓	
14	ENT0020		✓	10568973	13A	✓	✓	✓	—	19.99		✓	
15	ENT0021		✓	10568975	13A	✓	✓	✓	—	19.99		✓	
16	ENT0022		✓	10568972	13A	✓	✓	✓	—	19.99		✓	
17	ENT0023		✓	98530605	13A	✓	✓	✓	—	19.99		✓	
18	ENT0024		✓	98530607	13A	✓	✓	✓	—	19.99		✓	
19	ENT0025		✓	98530606	13A	✓	✓	✓	—	19.99		✓	
20	ENT0026		✓	98530604	13A	✓	✓	✓	—	19.99		✓	
21	ENT0027		✓	10568976	13A	✓	✓	✓	—	19.99		✓	
22	ENT0028		✓	98530601	13A	✓	✓	✓	—	19.99		✓	
23	ENT0029		✓	98530603	13A	✓	✓	✓	—	19.99		✓	
24	ENT0030		✓		13A	✓	✓	✓	—	19.99		✓	
25	ENT0031	✓	✓	801-122-5049671	13A	✓	✓	✓	00.10	19.99		✓	